

Appendix G:
Lists of Projects Not Yet Recommended

G(1): Retrofit Projects Not Yet Recommended
G(2): Generator Projects Not Yet Recommended

Shelter Retrofit List for 1999 and 2000 , 2001, 2002,2003,and 2004, 2005, and 2006 Projects
(new scores- 2006)

As of July 28, 2006
master-not-yet-recommended- generator projects

RP C	County	Site	Work	Costs	Risk Capacity Gained (spaces)	Contracted ?	Rank Score	Source of information	Technical Review: Recommended ?
8	Pasco	Zephyrhills HS/ Bldg 1 (1973)	Generator (\$176,232) (400kw) Generator Bldg: (\$171,599)	\$347,831	0		280	2005 Retrofit Report	No, if wall reinforcement done in previous HMGP project. ANSI A58.1-1982 Shutters SpNS shelter
8	Pasco	Pasco HS Bldgs A, B, & C (1964, 1992, 1986) 1992-Clinic Add 1986-Classroom Add	Generator (\$176,232) Generator bldg: (\$166,757)	\$342,989	0		259	2005 retrofit Report	No, >\$300k per site ANSI A58.1-1982 Shutters
1	Walton	Walton MS/ (1954/ 2002)	Generator (two-timer, gas)	\$30,000	0		232	2003 Retrofit List	No, appears to have unprotected windows. Needs further investigation.
1	Escambia	Pensacola Civic Center	Generator	\$579,658	0		230	2004 Retrofit List	No > \$300k / site
10	Palm Beach	Watson B. Duncan Community School	Generator : Replace generator/tank New automatic transfer switch New panels/feeders New central controls for ventilation	\$450,000	0		230	2002 Retrofit list	No > \$300k

Shelter Retrofit List for 1999 and 2000 , 2001, 2002,2003,and 2004, 2005, and 2006 Projects
(new scores- 2006)

As of July 28, 2006
master-not-yet-recommended- generator projects

RP C	County	Site	Work	Costs	Risk Capac ity Gaine d (space	Contr acted ?	Rank Scor e	Source of information	Technical Review: Recommended ?
10	Palm Beach	Wellington Landings MS	Generator : Replace generator/tank New automatic transfer switch New panels/feeders New central controls for ventilation	\$450,000	0		230	2002 Retrofit list	No, > \$300k
10	Palm Beach	William T. Dwyers HS	Generator : provide a new automatic transfer switch provide new panels/feeders provide central controls for ventilation systems on emerg power	\$450,000	0		230	2002 Retrofit list	No, > \$300k
7	Hardee	Zolfo springs ES Bldg 01 (1967)	Generator (30kw)	\$24,028	0		225	2005 Report	No unreinforced masonry walls, open spans. 1967
7	Hardee	Zolfo springs ES Bldg 02	Generator (30kw)	\$24,028	0		225	2005 Retrofit Report	No, unreinforced walls, 62 ft open span, 1967 const.
8	Manatee	Manatee Technical	Generator	\$413,625	0		217	2000 Retrofit	No >\$300k, facility constructed

Shelter Retrofit List for 1999 and 2000 , 2001, 2002,2003,and 2004, 2005, and 2006 Projects
(new scores- 2006)

As of July 28, 2006
master-not-yet-recommended- generator projects

RP C	County	Site	Work	Costs	Risk Capacity Gained (space	Contracted ?	Rank Score	Source of information	Technical Review: Recommended ?
		Institute Special Needs Shelter	w/enclosure					list per county email	to meet SREF per EMPA grant
10	Martin	Pinewood ES Bldgs 3, 4, 7,8, 9 (1988)	Generator- (250KW) portable, plus installation of panel and conduit	\$316,559	0		215	2005 Retrofit Report	No, >\$300,000 per site SBC-1988, shutters, Café- 66'-8" Span, 9'-4" overhang
3	Dixie	Anderson ES Whole campus	Generator (300kw) (\$80,000) Gen. Prewire: (\$15,000)	\$95,000	0		210	2005 Report List	No, large overhangs, unreinforced masonry walls, unverified loadpaths, unprotected windows.
10	Palm Beach	Bear Lakes MS	Generator : Replace generator/tank New automatic transfer switch New panels/feeders New central controls for ventilation	\$450,000	0		205	2002 Retrofit list	No >\$300k
10	Palm Beach	Glades Central HS	Generator : provide a new automatic transfer switch provide new panels/feeders provide central controls for	\$450,000	0		205	2002 Retrofit list	No >\$300k

Shelter Retrofit List for 1999 and 2000 , 2001, 2002,2003,and 2004, 2005, and 2006 Projects
(new scores- 2006)

As of July 28, 2006
master-not-yet-recommended- generator projects

RP C	County	Site	Work	Costs	Risk Capac ity Gaine d (space	Contr acteed ?	Rank Scor e	Source of information	Technical Review: Recommended ?
			ventilation systems on emerg power						
10	Palm Beach	Lake Worth MS	Generator : Replace generator/tank New automatic transfer switch New panels/feeders New central controls for ventilation	\$450,000	0		205	2002 Retrofit list	No, >\$300k
5	Sumter	North Sumter PS/ Cafeteria Bldg 18	Generator	\$153,545	0		200	2002 list moved from 2000 list	no, open span issues
5	Sumter	Webster ES/ Café Bldg 14	Generator	\$83,500	0		200	2002 list moved from 2000 list	no, long span not addressed.
9	Lee	TECO Arena Hurricane Shelter	Generator 1500 kw generator and modifications	\$450,000	0		197	2002 Retrofit list	No, >\$300K
10	Martin	Bessey Creek ES Bldgs 1, 2, 3, 4,5,6 (1995)	Generator- install generator (300kw) to include panel and	\$370,141	0		190	2005 Shelter Retrofit	No, > \$300,000 per site ARC 4496 Questionnaire- no lrdm.

Shelter Retrofit List for 1999 and 2000 , 2001, 2002,2003,and 2004, 2005, and 2006 Projects
(new scores- 2006)

As of July 28, 2006
master-not-yet-recommended- generator projects

RP C	County	Site	Work	Costs	Risk Capacity Gained (space	Contracted ?	Rank Score	Source of information	Technical Review: Recommended ?
			local conduit. Power for emergency lighting in all classrooms, restrooms, kitchen, café and admin area.						Cafe-SBC-1988, 74 long span. Has shutters. 9'-8" overhang.
10	Martin	Indiantown MS Bldgs 1, 2, 3, 4 (1969,1980, 1999)	Generator (50kw)-portable and installation of panel/local conduit	\$102,934	0		190	2005 Retrofit Report	No, large overhang, open span not addressed Arc 4496 questionnaire SBC-1988, Café-66'-8" span, 9'-4" overhang. Shutters. .
10	Martin	Felix A. Williams ES bldg 2, 4, 5, 6 (1993)	Generator- (330KW) portable and installation of panels and local conduits	\$370,141	0		180	2005 Retrofit Report	No, >\$300,000 per site ARC 4496 Questionnaire- no lrdm. Cafe-SBC-1988, 74 long span. Has shutters. 9'-8" overhang.
10	Palm Beach	Carver Community MS	Generator : Replace generator/tank New automatic transfer switch New panels/feeders New central controls for ventilation	\$450,000	0		180	2002 Retrofit list	No >\$300k
10	Palm Beach	Olympic Heights	generator -provide a	\$450,000	0		180	2002 Retrofit	No > \$300k

Shelter Retrofit List for 1999 and 2000 , 2001, 2002,2003,and 2004, 2005, and 2006 Projects
(new scores- 2006)

As of July 28, 2006
master-not-yet-recommended- generator projects

RP C	County	Site	Work	Costs	Risk Capac ity Gaine d (space	Contr acted ?	Rank Scor e	Source of information	Technical Review: Recommended ?
		Community HS	new automatic transfer switch provide new panels/feeders provide central controls for ventilation systems on emerg power.					lists	
10	Palm Beach	Omni MS	Generator - Replace generator fuel tank with new tank New automatic transfer switch New panels/feeders central controls for ventilation systems	\$350,000	0		180	2002 Retrofit list	No, > \$300k
1	Escambia	Olive Baptist Church North Wing and Rec Outreach Center (ROC) (1985/1997)	Generator	\$225,000	0		176	2003 retrofit list	No, pending questions on usage unreinforced masonry walls
10	Martin	Crystal Lake ES Bldgs 3, 4, 7, 8, 9 (1989)	Generator- install portable generator (250kw) to include panel and local	\$316,559	0		175	2005 Shelter Retrofit	No, >\$300,000 per site ARC 4496 questionnaie- no lrdm SBC-1988, 67ft span over Caf�.

Shelter Retrofit List for 1999 and 2000 , 2001, 2002,2003,and 2004, 2005, and 2006 Projects
(new scores- 2006)

As of July 28, 2006
master-not-yet-recommended- generator projects

RP C	County	Site	Work	Costs	Risk Capac ity Gaine d (space	Contr acted ?	Rank Scor e	Source of information	Technical Review: Recommended ?
			conduit. Power for emergency lighting in all classrooms, restrooms, kitchen, café and admin area.						9'-4" overhang shutters
10	Palm Beach	Boca Raton, City of Police/Fire training facility (1991) (two-story)	Generator	\$80,000	0		172	2003 Retrofit List	No- retrofit not done. Total cost of \$920,000
10	Martin	Jensen Beach ES Bldg 2, 3, 8 (1970,1980, 1987,1993)	Generator (200kw)- fixed with fence and slab. Install panel and conduit.	\$365,206	0		165	2005 Retrofit Report	No, >\$300,000 per site Arc 4496 questionnaire, ANSI A58.1-1982, shutters, Café- 60' span,
6	Volusia	Debary ES / Bldg 4 (cafeteria) Daytona Beach	Generator : Emerg. Prewiring	\$50,000	0		150	2001 Retrofit List Per data from county received 12/06/00- 09:36 AM. Updated per DEM Retrofit Review	No. Soft spots, roof overhangs (7'10") and roof open span (80'). Requires ASCE 7 review. LRDM attached

Shelter Retrofit List for 1999 and 2000 , 2001, 2002,2003,and 2004, 2005, and 2006 Projects
 (new scores- 2006)

As of July 28, 2006
 master-not-yet-recommended- generator projects

RP C	County	Site	Work	Costs	Risk Capac ity Gaine d (space	Contr acted ?	Rank Scor e	Source of information	Technical Review: Recommended ?
		#projects: 28		\$8,690,744	0				