

2008 Shelter Retrofit Report- Appendix F - List of Recommended Projects - Generators

RPC	County	Site	Bldg # / type	Work	Costs	Risk Capacity Gained (spaces)	Rank Score	SRR-YR	Tech Revw Recomm.?
9	Charlotte	Kingsway Es Bldg 1 Bldg 1 Two- story (1998)		Generator/ enclosure	\$101,000	0	326	2005	Yes
7	DeSoto	Turner Center Exhibit Hall		Generator (50kw- fixed)	\$23,595	0	318	2004	Yes
7	DeSoto	Turner Center Exhibit hall		Generator (50kw- portable) plus prewire	\$36,995	0	318	2004	Yes
7	Hardee	South Florida Comm. College Campus Main bldg.	main	Generator (400REOZD liquid cooled-diesel) and connections. alternate to existing 150kw generator (does not power A/c)	\$205,000	0	318	2005	Yes
3	Dixie	Old Town ES	all	Gen. Prewire- Retrofit Transfer Switch (\$50,000) Add large fuel cell- (\$40,000)	\$90,000	0	281	2005	Yes
7	DeSoto	DeSoto MS	Bldg E Gym	Generator (100kw)	\$40,000	0	266	2007	Yes
7	Hardee	Bowling Green ES	Bldg 18	Generator (30kw)- purchase and install	\$24,028	0	266	2005	Yes
7	Hardee	North Wauchula ES	Bldg 3	Generator (30kw) purchase & install	\$24,028	0	266	2005	Yes
7	Hardee	Zolfo Springs ES	Bldg 10	Generator (30kw) install	\$24,028	0	266	2j005	Yes
7	Hardee	Hardee Junior HS Bldg 1200, Media (2001)-Bldg 15?	Bldg 1200	Generator (30kw) and install.	\$24,028	0	264	2005	Yes
8	Pasco	Long Leaf ES Bldg 4 (2004)	Bldg 4	Generator: 155KW (\$92,954) Generator Housing: (\$136,498)	\$229,092	0	263	2005	Yes
8	Pasco	R.B. Stewart MS/ Cafeteria (2005)	Café	Generator (\$47,810) Generator Bldg: (\$158,285)	\$206,095	0	263	2005	Yes
8	Pasco	Schrader ES Bldg 9 2003- two story Classroom Addition	Bldg 9	Generator (\$105,303) Generator Bldg: (\$136,498)	\$241,801	0	263	2005	Yes

2008 Shelter Retrofit Report- Appendix F - List of Recommended Projects - Generators

RPC	County	Site	Bldg # / type	Work	Costs	Risk Capacity Gained (spaces)	Rank Score	SRR-YR	Tech Revw Recomm.?
8	Pasco	Seven Oaks ES Bldg 4 (2004)	Bldg 4	Generator (\$92,594) Generator Bldg: (\$136,498)	\$229,092	0	263	2005	Yes
8	Pasco	T. Weightman MS/ Bldg 2, 4, 7, 8 (1990)	Bldg 2,4,7,8	Generator (230kw) Generator Bldg: (\$184,745)	(\$125,048) \$310,793	0	263	2005	Yes
8	Pasco	Wesley Chapel District Park		Generator Installation	\$156,031	0	263	2005	Yes
8	Pasco	Wiregrass HS Bldgs 3, 4, 7 (2004)	Bldg 3, 4, 7	Generator (230kw) Generator Bldg: (\$136,498)	(\$116,197) \$252,695	0	263	2005	Yes
7	Hardee	Wauchula ES	Bldg 06	Generator (30kw) install	\$24,028	0	262	2005	Yes
7	Hardee	Wauchula ES	Bldg 05	Generator (30kw) Purchase & install	\$24,028	0	262	2005	Yes
8	Pasco	Calusa ES Kindergarten (1979, 1986)	Kindergarten	Generator 100KW (\$50,836) Generator Bldg (\$136,498)	\$187,334	0	259	2005	Yes
8	Pasco	Lacoochee ES/ Bldg 11, 12, 13 (1971, 1987)	Bldg 11, 12, 13	Generator 350KW (\$144,762) Generator Housing: (\$136,498)	\$281,260	0	249	2005	Yes
7	Okeechobee	County Health Department Special Needs Shelter		Generator 150KW	\$25,650	0	247	2001	Yes
10	St. Lucie	F.K. Sweet ES Bldg 8 Cafeteria (1987)	bldg 8	Generator- 200 KW portable generator with 3-day fuel tank on trailer to power 100Amp main panel	\$212,601	0	236	1999	yes
3	Dixie	Ruth Rains MS whole school	all	Generator (500kw) (\$150,000) Gen. Prewire	\$150,000	0	231	2005	Yes
6	Brevard	Pinewood ES	Bldg 4	Generator	\$195,000	0	226	1999	Yes
6	Brevard	South Mainland Community Center/ Gymnasium	Gym	Generator	\$185,000	0	226	2000	Yes

2008 Shelter Retrofit Report- Appendix F - List of Recommended Projects - Generators

RPC	County	Site	Bldg # / type	Work	Costs	Risk Capacity Gained (spaces)	Rank Score	SRR-YR	Tech Revw Recomm.?
6	Brevard	Port St. John Community Center	Center	Generator	\$185,000	0	224	2000	Yes
5	Sumter	North Sumter IS/ Café Bldg 18	Bldg 18	Generator	\$133,972	0	219	2002	Yes
5	Citrus	Citrus Senior HS Building # Cafeterium (2002/3)		Generator obtain and install portable generator (22KW)	\$36,500	0	218	2003	Yes
5	Citrus	Citrus Senior HS Cafeterium		Generator (install and purchase 350kw) Gen. Prewire and enclosure	\$266,337	0	218	2005	Yes
5	Sumter	North Sumter PS/ Cafeteria Bldg 18	Bldg 18	Generator	\$153,545	0	217	2002	Yes
4	Nassau	Hilliard M/Senior HS CFI #119 2000-2001		Generator 500KW generator/ enclosure	\$250,000	0	216	2002	Yes
6	Osceola	Celebration HS Bldg 2 (2003)	Bldg 2	Generator	\$135,000	0	216	2004	Yes
6	Osceola	Harmony HS Bldg 2 (2004)	Bldg 2	Generator	\$137,950	0	216	2004	Yes
6	Lake	Spring Creek ES	1,4	Generator plus switch(500kw for \$148,500 and \$45,200 for switch)	\$193,700	0	214	2006 Retrofit	Yes
6	Osceola	Discovery Intermediate Bldg 2 (1999)	Bldg 2	Generator	\$108,000	0	214	2004	Yes
6	Lake	Seminole Springs ES	1,4	Generator and switch (500kw generator (\$148,500) and switch-\$45,200)	\$193,700	0	212	2006 Retrofit	Yes
6	Osceola	Kissimmee ES Bldg 4 (2002)	Bldg 4	Generator	\$177,000	0	212	2004	Yes
6	Osceola	Poinciana ES Bldg 4 (2003)	Bldg 4	Generator	\$88,900	0	212	2004	Yes

2008 Shelter Retrofit Report- Appendix F - List of Recommended Projects - Generators

RPC	County	Site	Bldg # / type	Work	Costs	Risk Capacity Gained (spaces)	Rank Score	SRR-YR	Tech Revw Recomm.?
10	Palm Beach	Palm Beach Community College Education and Training Center Bldg 1400	Bldg 1400	Generator -Electrical generator costs	\$90,000	0	209	2002	Yes
10	Palm Beach	New Hope Health & Education Center		Generator	\$130,000	0	207	2002	Yes
4	Nassau	West Nassau County HS / CFI #114 (2000-2001)		Generator 500kw generator/ enclosure	\$250,000	0	206	2002	Yes
6	Osceola	Reedy Creek ES Bldg 2	Bldg 2?	Generator and pre-wire	\$77,900	0	203	2006	Yes
6	Brevard	Imperial Estates ES, Bldg 5,6,7 & 8	Bldg 5,6,7,8	Generator	\$225,000	0	201	1999	Yes
6	Brevard	Melbourne HS/ Bldgs 1&8	Bldg 1,8	Generator	\$205,000	0	201	1999	Yes
6	Brevard	Rockledge HS		Generator	\$185,000	0	201	2001	Yes
6	Brevard	Central Jr. High, West Melbourne		Generator	\$195,000	0	199	1999	Yes
6	Brevard	Longleaf ES/ Melbourne		Generator	\$195,000	0	199	1999	Yes
6	Brevard	Westside ES Palm Bay		Generator	\$195,000	0	199	1999	Yes
10	Martin	Warfield ES Bldgs 15, 21 (bldg 21-2001) (bldg 15- 1979)	15, 21	Generator (300kw)- fixed with fencing and slab. Install panel and conduit	\$267,912	0	198	2005	Yes
10	Martin	Hidden Oaks MS Bldg 2, 3, 8 (1991)	2,3,8	Generator- (300kw) fixed with fencing-slab. Includes panels and conduit wiring.	\$267,912	0	196	2005	Yes
10	Martin	Jensen Beach HS Bldgs 1, 4, 5 (2004)	1,4,5	Generator- prewire- install panel and local conduit	\$32,431	0	196	2005	Yes

2008 Shelter Retrofit Report- Appendix F - List of Recommended Projects - Generators

RPC	County	Site	Bldg # / type	Work	Costs	Risk Capacity Gained (spaces)	Rank Score	SRR-YR	Tech Revw Recomm.?
10	Martin	Seawind ES	2,3,4,5,6	Generator (330KW) - portable- install panel and conduit.	\$370,141	0	192	2005	Yes
10	St. Lucie	Bayshore ES		Generator Protective enclosure for Generator Generator Prewire	\$15,600	0	192	1999	Yes
10	St. Lucie	Floresta ES		Generator Protective enclosure for Generator Generator Prewire Storage	\$18,800	0	192	1999	Yes
10	St. Lucie	Lakewood Park ES	Bldg 1, 2	Generator Protective enclosure for Generator Generator Prewire Storage	\$18,800	0	192	1999	Yes
10	St. Lucie	Morningside ES	Bldg 1	Generator Protective enclosure for Generator Generator Prewire Storage	\$18,800	0	192	1999	yes
10	St. Lucie	Parkway ES	Bldg 1	Generator Protective enclosure for Generator Generator Prewire Storage	\$18,800	0	192	1999	Yes
10	St. Lucie	Village Green ES		Generator Protective enclosure for generator Prewire	\$15,600	0	192	1999	Yes
10	St. Lucie	Windmill Pointe ES		Generator Protective enclosure for Generator Generator Prewire	\$15,600	0	192	1999	Yes
4	Nassau	New Yulee MS "BB" education/ cafeteria	café	Generator 300kw generator/ wiring/ switch	\$155,000	0	191	2002	Yes
10	St. Lucie	Port St. Lucie ES	bldg 17	Café Generator- 200 KW portable generator with 3-day fuel tank on trailer to power 100Amp main panel	\$212,601	0	190	2005	Yes

2008 Shelter Retrofit Report- Appendix F - List of Recommended Projects - Generators

RPC	County	Site	Bldg # / type	Work	Costs	Risk Capacity Gained (spaces)	Rank Score	SRR-YR	Tech Revw Recomm.?
10	St. Lucie	White City ES/ Bldg 2 Cafeteria (1987)	Bldg 2 Café	Generator- 200 KW portable generator with 3-day fuel tank on trailer to power 100Amp main panel	\$212,601	0	190	2005	Yes
6	Osceola	Narcoossee Community School Bldg 2 (1998)	Bldg 2	Generator	\$134,000	0	189	2004	Yes
10	St. Lucie	Fairlawn ES Bldg 3 (1987)	Bldg 3	Generator- 200 KW portable generator with 3-day fuel tank on trailer to power 100Amp main panel	\$212,601	0	188	2005	Yes
6	Osceola	Florida Christian College (1985) Chapman Center, Gym	Gym	Generator, transfer switch wi/associated wiring	\$146,000	0	185	2004	Yes
6	Brevard	Brevard CC- Cocoa Life Long Learning Center	Life Long Learning Centr	Generator (230kw)	\$185,000	0	182	2001 Report List Per county letter dated 09 Feb 01	Yes
6	Volusia	Daytona Beach Comm Col/ Bldg 5	Bldg 5	Generator Pre-wire G	\$20,000	0	179	2000	Yes
6	Volusia	Daytona Beach Comm. Col. Bldg 16	Bldg 16	Generator / Prewire	\$20,000	0	179	2000	Yes
6	Brevard	Central Reference Library (bldg #1)	Bldg 1	Generator	\$200,000	0	176	2000	Yes
6	Brevard	Apollo ES	Bldgs 2,3,4	Generator	\$215,000	0	172	1999	Yes
6	Brevard	Brevard CC - Allied Health Bldg	Bldg 20	Generator (230KW) Freezer & oven/range	\$215,000	0	172	2001	Yes
6	Seminole	Lake Mary HS. Entire 1st floor (built 1979, additions 1983-1988)		Generator Prewiring	\$16,800	0	172	2001	Yes

2008 Shelter Retrofit Report- Appendix F - List of Recommended Projects - Generators

RPC	County	Site	Bldg # / type	Work	Costs	Risk Capacity Gained (spaces)	Rank Score	SRR-YR	Tech Revw Recomm.?
2	Jackson	Graceville HS Bldg 2 (2001)	Bldg 2	Generator: 60kw	\$36,159	0	164	2002	Yes
2	Jackson	Malone SHS Bldg 14 (2001)	Bldg 14	Generator: 60kw	\$36,159	0	164	2002	Yes
1	Okaloosa	Antioch ES		Generator Add Emergency Generator	\$50,000	0	164	2000	Yes
6	Brevard	Space Coast MS		Generator	\$195,000	0	153	1999	Yes
1	Escambia	Lipscomb	Bldg 1	Generator and Generator Pre-wire (400kw generator)	\$149,110	0	151	2005	Yes
1	Escambia	Univ of West Fla	Bldg 13	Generator (500kw) /Prewire	\$90,000	0	151	2001	Yes
1	Holmes	East Pittman Evacuation Shelte		generator	\$20,000	0	141	2001	Yes
Totals:		#Projects:	80		\$10,892,133	0			